

ADDENDUM TO THE CONTRACT DOCUMENTS	Page Number 1	No. of Pages 1
Addendum No. Two	Date Addendum Issued: April 10, 2019	
Issuing Office Department of Natural Resources Support Services Division Procurement Section 550 West 7 th Ave., Suite 1330, Anchorage, Alaska 99501 Phone: 269-8666 Fax: 269-8909	Previous Addenda Issued One	
Project: Kodiak Habitat Enhancement Project Magazine Area Project No.: ITB 10-004-19	Date and Hour of Quotes Due April 18, 2019 at 2:00 PM. (UNCHANGED)	

NOTICE TO BIDDERS

Bidder must acknowledge receipt of this addendum prior to the hour and date set for the quotes being due by one of the following methods:

- By acknowledging receipt of this addendum on the quote submitted.
- By telegram or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any quote received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a quote already submitted, such modification may be made by telegram or telefacsimile provided such a telegram or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

Bid Documents:

The following changes are being made to the ITB:

- BID SCHEDULE A, Line item 204(1) Select Fill Material Type A1 appears twice. Please strike through the second occurrence of that line item or just ignore it and leave it blank. That bid item should only appear once.

Following are questions that have been asked by potential bidders. Answers are shown in ***bold italicized*** text directly after the question.

- Please clarify if there is a DBE Utilization requirement for this project and if documentation needs to be submitted with the bid. ***See the Federal EEO Bid Conditions contained in ITB documents. Contractors must document good faith effort. There is no documentation required with the bid, but the EEO-1 Certification must be signed before contract award.***
- Under Bid Schedule A, Item 204(1) Select Fill Material Type A1 is listed twice. Please clarify. ***See Changes section above.***
- It appears the Fish Habitat Permit for Culvert #20703259 is not in the bid packet. Please supply if there is one or clarify if one is not required for this area. ***A permit is not required per ADFG Habitat Biologist.***
- It appears the final surface course on the bottom of the channel after removal of Culvert 20703471 is native soil. It also appears the temporary filter structure at Culvert 20703471 is meant to be removed from service after the excavation has been performed on the channel. The NOT wouldn't be able to be filed without all surfaces stabilized. As this will likely be an erodible surface, should a permanent system be left in place for future fine material collection? Or is there a better finish material that could be installed on this surface? ***The plan details are correct as shown.***
- Please verify if access to Culvert 20703471 along the vegetated gravel causeway is allowed. The limit of disturbance shown on Sheet C-502 does not allow for access of construction equipment. ***The plan details are correct.***

6. When will the owner furnished box culvert and other culvert materials be available? Will all of the materials be arriving at the same time? **Materials are expected to arrive on island on June 08th. All culverts are to arrive at the same time.**
7. The General Requirements section of the specifications require Sites #20703471, 10103253, and 10103256 to be complete by 9/30/19. The Nesting Bird Window prohibits the clearing of vegetation from 4/15 to 7/15. The Fish Habitat Permits for these areas have a stipulation that prohibits work in the flowing channels of Battery Creek between 7/31 to 10/31. This leaves just a 2-week window from 7/16/19 to 7/30/19 to perform this portion of the work. Please verify these are the requirements. **This project completion date allows for work to continue during this summer and next. Projects should be planned accordingly.**
8. Under the Road and Trail Closures section of the General requirements, it's unclear as to how long access can be cut off to the firing range. Please clarify. **Work in the magazine area will be coordinated with the Chief Gunners Mate to allow for a reasonable construction timeframe.**
9. What will the process be for access to the Magazine Area? Do we need a Military Police escort there full time? Will the employees need to be badged through Rapid Gate? **Rapid Gate will not be necessary for this project. Contact MilPol to have the gate opened prior to work and at the end of the day to have the gate secured.**
10. How will the project be reviewed for basis of award? Will the addition of all Bid Schedules A through G be the basis of award, as shown in the Summary Bid Schedule after Bid Schedule G? **Yes, you are correct. Award will be based on the Total Bid Amount shown on the Summary Bid Schedule. The Total Bid Amount consists of the sum of the Total Basic Bid amounts for all schedules A through G.**
11. Does the owner have funds to award all Bid Schedules A through G? Is it a possibility that only certain Bid Schedules will be awarded? Is there a priority list of which Bid Schedules would be awarded by importance? **See answer to number 10 above. Also, we do anticipate having enough funds to award all work.**
12. Has a SHPO Permit been acquired by the Owner? **Yes**
13. Numerous notes on the revegetation plans reference mixing topsoil in to the Collar Riprap. Is this subsidiary to the Riprap work, or will it be paid for at the topsoil and seed unit price? **Topsoil for the collar riprap will be incidental to this unit price.**
14. During the establishment period for the vegetative mat along the waterways, will the Engineer need to be notified and present for each of the deep watering sessions as shown in Spec Section 690-3.07? **Yes**
15. Has there been any geotechnical investigations performed at the sites? If so, please provide this information. **No**

There are no further changes to the ITB at this time.

Bidders are required to acknowledge this addendum on the proposal form or by FAX prior to the quotes being due.

Addendum Number Two (2) received.

Name/Title

Date

Firm

END OF ADDENDUM