



THE STATE
of **ALASKA**
GOVERNOR SEAN PARNELL

Department of Corrections
DIVISION OF ADMINISTRATIVE SERVICES
Anchorage Procurement Section

550 W. 7th Avenue, Suite 1860
Anchorage, AK 99501-3570
Tele: 907.269.7344
Fax: 907.269.7345
Email: gary.bailey@alaska.gov

April 8, 2014

ATTN: Vendors

RE: Project Name: Fire Alarm System Inspection & Maintenance Svcs
Project Location: Goose Creek Correctional Center
Project Number: 20-14-GCCC

ADDENDUM #2

The Department of Corrections is issuing this Addendum to the Invitation to Bid for the above project.

Question / Reply as follows:

Q - Can you clarify the inclusion of the graphic display of the Siemens Smoke Control System with the Fire Alarm System and Maintenance. To my knowledge it is a component of the HVAC control system.

A - *The NFPA 72 that covers the inspections (2007 edition) does address this question. The inspection for HVAC equipment is covered under Table 10.4.2.2 "Test Methods". Section #23 Fire Safety Functions lists test frequency for fire safety functions shall be the same frequency as required for initiating devices that activate the fire safety function. If the system is manually activated at the control room it should be inspected/activated and verified that it is functional.*

End of Changes for Addendum #2

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your bid form.

Please contact me if you have any questions.

Sincerely,

ORIGINAL SIGNED

Gary Bailey
Procurement Specialist II