



State of Alaska
Department of Public Safety
Division of

Administrative Services

Sean Parnell, Governor
Gary Folger, Commissioner

TO: Bidders

DATE: July 25, 2014

FROM: Frank D. Whittington
Facilities Manager

SUBJECT: Department of Public Safety, Anchorage, Alaska
Anchorage HQ Secure Entry Project
Project: 12-133406F

Addenda #1

DATE: July 25, 2014
PROJECT NO: 12-133406F
PROJECT NAME: **Anchorage HQ Secure Entry Project**

PROJECT LOCATION: The work site is located at the Department of Public Safety, Alaska State Trooper Facility located at 5700 Tudor Road, Anchorage, Alaska 99507.

Questions on SCOPE OF WORK – ADDENDA # 1: Questions & clarifications asked at pre-bid meeting.

- Delete all work related to tile logo demo and installation (12' x 21'2" carpet demo & install tile with logo). This work will be bid at a later time once the details are worked out after the completion of this project. It will be put out as a separate project.
- Add 16"H x 24"W Level III fixed pane window. A blind spot to the entrance was noted so need to add to the AST side next to new window being installed. Note: A T-stat may need to be relocated down approx. 6" next to a security card reader.
- Contractor will demo two (2) existing work stations to perform the previously outlined work with the Level III windows, doors, and ballistic panels. Contractor will provide two new matching work stations similar in functionality to the existing in regards to space, drawers, & cabinets. (Submittals will be required)
- Plan work hours at this time for bidding purposes to be normal 8 am to 5 pm daily, no weekends. If it is determined that a different work schedule can be maintained it will be dealt with by Change Order.

Bid Closing Date remains the same, Monday, August 04, 2014 @ 1:00 AT.

Please ensure you acknowledge receipt of this addendum on your proposal. If you do not acknowledge receipt of this addendum your bid will be non-responsive.

Sincerely,

D. Whittington

Frank D. Whittington
Facilities Manager
Department of Public Safety
Phone: 907-561-1092 X223 Fax: 907-561-9178