

Addendum 2

Ketchikan Pioneer Home Boiler Replacement - JNU 16-04C

This addendum addresses questions posed by potential bidders, provides additional information and makes clarifications to the bid documents.

General - NONE

Project Manual - NONE

Drawings - Ketchikan Pioneer Home – Boiler Replacement

Sheet M2 Mechanical Specifications

ADD the following specifications:

“HYDRONIC PIPING”

Steel Pipe: ASTM A53, Schedule 40, black.

Fittings: ASME B16.3, malleable iron or ASTM A234, forged steel welding type.

Joints: Threaded for pipe 2 inches and smaller; welded for pipe 2-1/2 inches and larger.

Steel Pipe: ASTM A53, Schedule 40, black, grooved joint pipe

Fittings: ASME B16.3, malleable iron or ASTM A234, forged steel welding type.

Joints: Threaded for pipe 2 inches and smaller; welded for pipe 2-1/2 inches and larger.

Pro-Press piping system is allowed.

Sheet M7 Piping Schematics: Detail 2 – Heating Piping Schematic - Remodel

DELETE the following note: “Install new circuit sensor flow meter in accordance with manufacturer’s recommendations.”

DELETE the following note: “Model OP-3A, B&G circuit sensor flow meter or equal.” A total of 4 Circuit Sensor Flow Meters are to be deleted.

All other conditions remain unchanged. If you have any questions, please contact Keith Stephens, HSS Project Manager.

Issue Date: February 11, 2016

Issued By: Keith Stephens, Project Manager

Contractor must acknowledge receipt of this addendum on the Bid Form to avoid being disqualified.

**Thank You,
Keith Stephens, Facilities Manager
HSS/Facilities
907 465-1872 work
907 465-2607 fax
keith.stephens@alaska.gov**