



STATE OF ALASKA
DEPARTMENT OF ADMINISTRATION
DIVISION OF GENERAL SERVICES

INVITATION TO BID

ADDENDUM TO THE CONTRACT

2017-0222-3531

Douglas Island Building OAH TI and Ventilation Upgrades

ADDENDUM NO.: Four

CURRENT BID DUE DATE:

February 6, 2017, 2:00 p.m. Local Time

PREVIOUS ADDENDA: Three

PREVIOUS BID DUE DATE:

February 6, 2017, 2:00 p.m. Local Time

ISSUED BY:
Statewide Facilities
Division of General Services
Department of Administration
P.O. Box 110210
Juneau, Alaska 99811-0210

DATE ADDENDUM ISSUED: January 25, 2017

The following items change and clarify the Contract and all other terms and conditions remain the same.

Item No. 1:

Where acoustic walls meet exterior wall, trim convactor cover to terminate on each side of wall. Seal heating pipe penetration at new acoustic wall. Box wall around electrical raceway and seal penetration.

Item No. 2:

Contractor is to carefully remove existing carpet tile in the work area and turn over to the owner's flooring contractor for reinstallation at completion of construction.

By: Kami Bartness
Kami Bartness, Facilities Contracting Officer III

Total number of pages contained within this Addendum: 1

END OF ADDENDUM No. 4