



STATE OF ALASKA
DEPARTMENT OF ADMINISTRATION
DIVISION OF GENERAL SERVICES

INVITATION TO BID

ADDENDUM TO THE CONTRACT

2017-0222-3531

Douglas Island Building OAH TI and Ventilation Upgrades

ADDENDUM NO.: Six

CURRENT BID DUE DATE:

February 6, 2017, 2:00 p.m. Local Time

PREVIOUS ADDENDA: Five

PREVIOUS BID DUE DATE:

February 6, 2017, 2:00 p.m. Local Time

ISSUED BY:
Statewide Facilities
Division of General Services
Department of Administration
P.O. Box 110210
Juneau, Alaska 99811-0210

DATE ADDENDUM ISSUED: February 2, 2017

The following items change and clarify the Contract and all other terms and conditions remain the same.

Item No. 1:

Question: In Section 087100, 1.6 "maintenance materials", it lists 5 locksets, 10 hinges, 5 closers as needed. Is this needed, or was this left over from an original spec?

Answer: Not needed

Item No. 2:

Question: Note 5 on sheet A2.0 says the wood doors should be STC 50, but the finish hardware in section 087100 does not reflect this. Nor does the spec section 081416 for the wood doors. Please clarify intent.

Answer: Submit doors with an acoustic rating. Target is STC 50.

By: Kami Bartness
Kami Bartness, Facilities Contracting Officer III

Total number of pages contained within this Addendum: 1
END OF ADDENDUM No. 6