



LIGHT FIXTURE SCHEDULE								
TYPE	LOCATION	MANUFACTURER AND CATALOG NUMBER (OR APPROVED EQUAL)	LUMINAIRE DESCRIPTION	MOUNTING		LAMPS	BALLAST/DRIVER	TOTAL INPUT WATTS
				TYPE	HEIGHT			
A	OFFICES	FINELITE #S16 LED-ID-DC0-4-3E-S/H -FT0-940-277-SC-FA-FE	NOMINAL 2"x7.5" DIRECT/INDIRECT, 3 LIGHT ENGINES, STANDARD OUTPUT UP, HIGH OUTPUT DOWN, SINGLE CIRCUIT, FULL ADJUSTABLE MOUNTING, FLAT ENDCAP.	PENDANT	7'	4000K 3226L	277V INTEGRAL 0-10V 1% DIMMING DRIVER	37
B	CLASSROOM	FINELITE #HPR LED-A-1X4-DC0-S- 940-277V-SC	1'x4' RECESSED LED LUMINAIRE, STEEL HOUSING, DIFFUSED ACRYLIC LENS, ANGLED LUMINAIRE, SINGLE CIRCUIT.	RECESSED	CEILING	4000K 3099L	277V INTEGRAL 0-10V 1% DIMMING DRIVER	29
B1	AV ROOM	FINELITE #HPR LED-A-2X4-DC0-S- 940-277V-SC	SAME AS TYPE 'B' EXCEPT 2'x4'.	RECESSED	CEILING	4000K 3772L	277V INTEGRAL 0-10V 1% DIMMING DRIVER	27
B2	CLASSROOM	FINELITE #HPR LED-A-1X2-DC0-S- 940-277V-SC	SAME AS TYPE 'B' EXCEPT 1'x2'.	RECESSED	CEILING	4000K 1511L	277V INTEGRAL 0-10V 1% DIMMING DRIVER	16
C	RECEPTION	FINELITE #HP-4R-S-940-277V-SC	SEAMLESS LINEAR RECESSED LED, ALUMINUM HOUSING, LENSED. (SEE PLANS FOR LENGTH)	RECESSED	CEILING	4000K 1525L	277V INTEGRAL 0-10V 1% DIMMING DRIVER	3.6W/ FT
D	LAB/CASE	FINELITE #UC-E-SILVER #PS-60	UNDERCABINET LIGHT, ON-BOARD DIMMING, SILVER FINISH. SEE PLANS FOR LENGTHS, PROVIDE REMOTE DRIVER SIZED FOR UNDERCABINET LIGHT.	SURFACE	UNDER-CABINET	4000K 190L/FT	REMOTE 120-277/24V LED DRIVER	4W/ FT
F	CLASSROOM	FINELITE #HP-4-WW-R-K-8'-S-940 -277V-SC	8' LINEAR WALLWASH, ALUMINUM HOUSING, KICKER REFLECTOR, SINGLE CIRCUIT.	RECESSED	CEILING	4000K 1488L	277V INTEGRAL 0-10V 1% DIMMING DRIVER	32
X	EGRESS	DUAL LITE #LE-C-S-G-X-N-A	EDGE LIT EXIT SIGN, ACRYLIC BODY, ALUMINUM TRIM, GREEN LETTERING, SATIN ALUMINUM FINISH.	SURFACE	CEILING	LED	120/277V LED DRIVER	2.5

NOTES:

1. VERIFY CEILING GRID TYPE PRIOR TO ORDERING.

LEGEND			
	EMERGENCY EXIT LIGHT - SURFACE MTD CLG		WIRELESS ACCESS POINT
	EMERGENCY EXIT LIGHT - SURFACE MTD WALL		MAGNETIC STRIPE CARD READER
	EMERGENCY FIXTURE - RECESS MTD		ELECTRIC STRIKE - SPECIFIED UNDER DIVISION 8
	LINEAR LIGHT FIXTURE - RECESS MTD		RECESSED DOOR CONTACT - SPECIFIED UNDER DIVISION 8
	PENDANT MTD FIXTURE		MICROPHONE OUTLET - # INDICATES NUMBER OF JACKS
	LINEAR LIGHT FIXTURE - WALL MTD		FIRE ALARM HORN/HORN - WALL MOUNTED
	FIXTURE TAG (LETTER INDICATES TYPE)		PHOTOELECTRIC SMOKE DETECTOR
	SINGLE POLE SWITCH		DUPLEX RECEPTACLE TO BE REMOVED (DASHED OR DOTTED LINES INDICATE ITEMS TO BE REMOVED TYPICAL)
	DIMMER SWITCH		NOTE TAG (No. INDICATES NOTE)
	0-10V OCCUPANCY SENSOR DIMMER SWITCH		DOOR TAG
	LOW VOLTAGE LIGHTING WALL STATION	AC	ABOVE COUNTER
	CONDUIT, CONCEALED	AFF	ABOVE FINISHED FLOOR
	NUMBER AND SIZE OF WIRES (NO MARKS = 3 #12)	C	CONDUIT
	HOMERUN TO PANEL (PANEL AND CIRCUIT No.)	CLG	CEILING
	EXISTING PANEL	E, (E)	DENOTES EXISTING ITEM
	EXISTING MAIN DISTRIBUTION PANEL	EM	DENOTES EMERGENCY POWER
	DUPLEX RECEPTACLE	GTD	GENERATOR TRANSFER DEVICE
	DUPLEX RECEPTACLE WITH (2) USB POWER PORTS	LED	LIGHT EMITTING DIODE
	QUADRAPLEX RECEPTACLE	NAC	NOTIFICATION APPLIANCE CIRCUIT
	RECEPTACLE FLOOR OUTLET - DUPLEX RECEPTACLE	OFOI	OWNER-FURNISHED, OWNER-INSTALLED
	JUNCTION BOX	OFCI	OWNER-FURNISHED, CONTRACTOR-INSTALLED
	EXISTING TELECOMMUNICATIONS OUTLET	R	DENOTES EXISTING ITEM THAT HAS BEEN RELOCATED
	CATEGORY 6A TELECOMMUNICATIONS OUTLET (NUMBER INDICATES JACK QUANTITY, 2 IF NOT SHOWN)	TYP	TYPICAL
	CATEGORY 6A TELECOMMUNICATIONS FLOOR OUTLET (NUMBER INDICATES JACK QUANTITY, 2 IF NOT SHOWN)	TTB	TELEPHONE TERMINAL BOARD
		UON	UNLESS OTHERWISE NOTED

