


1

EXISTING CONTINUOUS WALL MOUNTED LIGHTING. DEMOLISH LIGHTING AT LOCATION INDICATED. REWORK LIGHTING TO DEAD END IN THE EAST AND WEST SIDES OF CLASSROOM. PROVIDE END CAP/COVER WITH COLOR MATCHING EXITING FINISH TO PROVIDE A CLEAN AND CONSISTENT APPEARANCE. INTERCEPT, EXTEND, AND RECONNECT LIGHTING CIRCUIT AS REQUIRED.



**Weidner Classroom
Remodel - #17-0033**
3416 Seawolf Drive Anchorage, AK
University of Alaska Anchorage

[illegible]

FILE NAME: x:\16616 uaaweidner\Dwgs\Edwg\sheet files\16616 - E100.dwg
PLOTTED: erp 3/15/2017 8:24 AM