



INVITATION TO BID ADDENDUM TO THE CONTRACT

Project Name: Community Building Generator Installation
Project Number: 2017-0222-3524

ADDENDUM #:	One
CURRENT BID OPENING DATE:	April 28, 2017 2:00 p.m. Local time

PREVIOUS ADDENDA:	none
PREVIOUS BID OPENING	April 28, 2017 2:00 p.m. Local time

ISSUED BY:	Statewide Facilities Physical Address: Department of Administration Division of General Services 141 Willoughby Ave Juneau, Alaska 99801	Mailing Address: Department of Administration Division of General Services PO Box 110210 Juneau, Alaska 99811-0210
-------------------	---	---

DATE ADDENDUM ISSUED: April 18, 2017

The following items of the Contract are modified as herein indicated. All other items remain the same.

Drawings:

Item No. 1: Sheet E2.0, Site Plan – New – **Add:** “Note 4: Install generator annunciator panel inside of building main entrance adjacent to the fire alarm control panel. Provide ¾” conduit with required circuiting between generator and annunciator. Conduit shall be installed in building interior.”

Specifications:

Item No. 1: 263213.14 – Diesel Engine Generators, Section 2.9 B - **Replace** with “Description: prefabricated, galvanized-steel-clad, integral structural-steel-framed, attached to generator assembly. Provide brown paint finish, Confirm color with owner.”

END OF ADDENDUM No. 1

Brent Fagerstrom, Facilities Contracting Officer

Total number of pages contained within this Addendum: 1