



THE STATE
of **ALASKA**
GOVERNOR BILL WALKER

Department of Corrections

DIVISION OF ADMINISTRATIVE SERVICES
Anchorage Procurement Section

550 W. 7th Ave, Suite 1800
Anchorage, Alaska 99501-3569
Tel: 907.269.7344
Fax: 907-269-7345
Email: gary.bailey@alaska.gov

May 8, 2017

ATTN: Vendors

RE: ITB Name: Generator Reconfiguration
Location: Anchorage Correctional Complex - East
ITB Number: 170011738
ITB Due date: May 11, 2017 @ 1:30 PM AST

ADDENDUM # 8

The Department of Corrections is issuing this Addendum to the Invitation to Bid (ITB) for the above project.

The following ITB clarifications are provided below:

1. Vendor Question: Will DOC's generator be available to provide temporary power during the switchboard upgrade? If so, Will the contractor be required to provide or replenish fuel used?
 - a. State's Response: Yes. ACC will provide fuel for the generator.
2. Vendor Question: Please confirm the facility will be able to accommodate up to 6 pre-scheduled power outages, up to 8 hours each, for disconnecting & reconnecting equipment.
 - a. State Response: During the project, ACC will accommodate six (6) electrical power shutdowns. Each electrical power shutdown shall last no longer than eight (8) hours and occur between the hours of 10pm and 6am.

END of Changes

This addendum is considered part of the ITB and is to be acknowledged below and return to me prior to bid opening.

Please contact me if you have any questions regarding this Addendum.

Sincerely,



Evan Patterson for Gary Bailey
Procurement Officer

ACKNOWLEDGED BY: _____
(SIGNATURE)

DATE: _____

Print Name: _____ **Business Name:** _____