

Divisions		
No.	Date	Description
Design:	EJK/NPS/KTR	
Drawn:	ERP	
Date:	04/26/2017	
Sheet Title		
FIRST FLOOR PLAN SOUTH - FIRE ALARM DEMOLITION		
Sheet Number		

1. UNLESS OTHERWISE NOTED DEMOLISH ALL EXISTING FIRE ALARM DEVICES, APPLIANCES AND PANELS UNDER THE FIRE ALARM INSTALLATION WORK. EXISTING FIRE ALARM SYSTEM EQUIPMENT, DEVICE AND APPLIANCE QUANTITIES AND LOCATIONS SHOWN ARE BASED UPON AS-BUILT DRAWINGS AND LIMITED FIELD VERIFICATION. COORDINATE/PHASE DEMOLITION AND NEW WORK TO ENSURE THERE IS NO LAPSE OF FIRE ALARM SYSTEM COVERAGE. REFER TO SECTIONS 26 0000 ELECTRICAL GENERAL REQUIREMENTS AND 28 3100 ADDRESSABLE FIRE ALARM FOR SPECIFIC DEMOLITION AND FIRE ALARM SYSTEM REQUIREMENTS. 2. EXISTING MAGNETIC DOOR HOLDERS AND DOOR CLOSERS SHALL REMAIN AND SHALL BE CONNECTED TO AND CONTROLLED BY THE NEW FIRE ALARM SYSTEM.	3. DEMOLISH EXISTING FIRE ALARM CONNECTIONS AT ELEVATOR CONTROLLER. RECONNECT CONTROLLER TO NEW FIRE ALARM SYSTEM UNDER NEW WORK. REFER TO SPECIFICATION SECTION 28 3100 FOR ADDITIONAL INFORMATION.
--	---

