

FILE NAME: X:\17601 UABASFA\Drawg\Edwg\Sheet Files\17601 - E203.dwg
PLOTED: ejk 4/26/2017 11:51 AM



1 SECOND FLOOR PLAN NORTH – FIRE ALARM
E203 SCALE: 1/8" = 1'-0"

- SHEET NOTES
1.

FIRE ALARM NOTIFICATION STROBES SHALL BE 15 cd UNLESS OTHERWISE NOTED.
2.

INSTALL CEILING MOUNTED DEVICES IN CEILING TILES WITH EXISTING DEVICES INSTALLED IN THEM, WHERE PRACTICABLE, TO MAINTAIN THE MAXIMUM NUMBER OF ACCESSIBLE TILES WITH NO DEVICES INSTALLED IN THEM.
3.

CONNECT EXISTING MAGNETIC DOOR HOLDERS TO FIRE ALARM PANEL. PROVIDE POWER AND RELEASE CONTROL IN ACCORDANCE WITH SPECIFICATION SECTION 28 3100 – ADDRESSABLE FIRE ALARM SYSTEM.
4.

CONTRACTOR'S OPTION: REMOTE BOOSTER POWER SUPPLY/SUPPLIES MAY BE ADDED TO SERVE THE NOTIFICATION APPLIANCE CIRCUITS. CONTRACTOR SHALL SUBMIT LOCATION(S) FOR APPROVAL PRIOR TO THE SHOP DRAWING SUBMITTALS. IF THE OPTION IS EXERCISED, INCLUDE ALL COSTS ASSOCIATED WITH THE REMOTE BOOSTER POWER SUPPLIES AS PART OF THE BASE BID. INCLUDE A MULTI-TECHNOLOGY DETECTOR AT THE BOOSTER PANEL LOCATION.
- 5

PROVIDE DETECTOR FOR PHASE 1 ELEVATOR RECALL FUNCTIONALITY. LOCATE PER NFPA 72 REQUIREMENTS.
- 6

LOCATE DETECTOR FOR DOOR RELEASE WITHIN 5 FEET OF CENTERLINE OF DOORS. SHALL RELEASE LOCAL DOORS UPON ACTIVATION.

ENGINEERS

www.smc-engineers.com
Adams, Morgenstern & Co., Inc.
CoA No. C0342 - 907.257.9100
701 E. Tudor Rd., Suite 250
Anchorage, AK 99503

STATE OF ALASKA

49TH

Edward J. Kamlinski
04/26/2017
EE-105686
REGISTERED PROFESSIONAL ENGINEER

17601

UNIVERSITY OF ALASKA ANCHORAGE
RASMUSON HALL FIRE ALARM REPLACEMENT
PROJECT NUMBER 17-0071

Revisions		
No.	Date	Description
Design: EJK/NPS/KTR		
Drawn: ERP		
Date: 04/26/2017		
Sheet Title		
SECOND FLOOR PLAN NORTH - FIRE ALARM		
Sheet Number		
E203		