

DEPARTMENT OF HEALTH AND SOCIAL SERVICES
ALAKSA PSYCHIATRIC INSTITUTE INTERIOR IMPROVEMENTS
ANCHORAGE, AK

June 6, 2017, 2017

ADDENDUM NO. 2

TO: ALL PLAN HOLDERS

FROM: Steve Fishback, Architect

SUBJECT: Corrected Specifications
Project # ANC 17-33C

This addendum consists of:

1. Addendum document consisting of 2 pages
2. Corrected Specification: **SECTION 22 40 00 – Plumbing Fixtures**

Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

Note to Bidders: Bidders are required to acknowledge this addendum on the proposal form. The following additions, corrections, and changes are hereby made to the subject invitation to bid.

Notes:

- **Bid due date has been extended from Wednesday June 7, 2017 at 2:00pm to Monday June 12, 2017 at 2:00 p.m.**

CHANGES TO SPECIFICATIONS:

ITEM # CHANGES TO SPECIFICATIONS

1. **REPLACE:** Specification Section **22 40 00, Part 2.2 A** to read: Bowl, ANSI A112 19.2M. Floor mounted. Wall outlet, siphon jet, ligature resistant, 16 gage 304 stainless steel with white powder coating, 4-1/2" high close-coupled closet combination with elongated rim. Bowl height per ADA requirements. Provide with manufactured wedge to allow full seal of basin cover. Whitehall Ligature Resistant Water Closet, Model WH R2142 or approved equal.

2. **REPLACE: Specification Section 22 40 00 Part 2.2D** to read: Hydraulic Flush Valve: Existing flush valves to remain in place. Bed flush valve cover plates in sealant where identified to correct ligature attachment points

Issued by: Mark Moon, Project Manager

Issue Date: June 6, 2017

END OF ADDENDUM

