




NOTE- ALL UNDERGROUND BY OTHERS.
WORMALD START POINT @ 8" FLANGE 6" ABOVE FIN. FLR. INSIDE NEW BLDG. SEE DETAIL 4 FOR LOCATION.


8" WATER LINE (786'-0") BY OTHERS.




A/1 CROSS-SECTION
SCALE: ⅛" = 1'-0"




HANGER DETAIL 'T1'
SCALE: ½" = 1'-0"



B FIRE DEPT. CONN. DETAIL
NONE



SPRINKLER PLAN - HANGAR
SCALE: ⅛" = 1'-0"



SITE PLAN
SCALE: 1" = 50'-0"

FITTER/LISTER NOTES

1) SEND (8) EXTRA LENGTHS OF ⅜"ø x 10'0 HANGER ROD.
2) CTS = CUT TO SUIT.
3) ALL COUPLINGS FLEXIBLE UNO.
4) BRANCHLINES #6,9,+10 TO BE GRINNELL "XL" PIPE
5) ALL (T×F) PIECES TO BE GRINNELL "XL" PIPE
6) SEND EXTRA MATERIAL #2
7) SEND THE FOLLOWING WALL PLATES (SIZE-QTY) (¼"-1), (1"-2), (3"-2)

HANGER LEGEND

A	"U" HOOK
B	COACH SCREW ROD
C	"C" CLAMP
D	TOP BEAM CLAMP
E	EYE ROD
F	FLUSH SHELL
G	CEILING FLANGE
H	SIDE BEAM BRACKET
J	"J" BOLT
K	SHORT CLIP
L	"L" ROD
M	MACHINE THREADED ROD
N	TOGGLE NUT
P	POWDER DRIVEN STUD
R	WEDGE ANCHOR
S	SEE DETAIL
U	
V	
W	
X	
Y	

2-WAY EARTHQUAKE BRACE
4-WAY EARTHQUAKE BRACE
STRUCTURE TO CENTER LINE OF PIPE IN INCHES

SPRINKLER LEGEND

SPRINKLER SYMBOL	SPRINKLER ORIFICE SIZES AND TYPE		UPRIGHT	PENDENT	SIDE WALL
½"	⅜ ⅜ ⅜ ½ ½	SPRAY	○	◎	1/2
				⊙	1
¾"	⅜ ½	SPRAY	□	▣	3/4
				⊠	1
1"	⅜ ½ ½	SIDEWALL	◇	◈	1/2
				⊡	1
1"	1	DRY TYPE	◇	◈	1
				⊡	1

TEMP. RATING	SPRINKLERS DOWN AND UP	SPRINKLERS UP AND SIDEWALL	STOCK	ORDERING SYMBOL
165°				
212°				
286°				
350°				
500°				

SPRINKLERS USED

SYM	SPRINKLER ORIFICE SIZE, TYPE & FINISH	QUAN	TEMP.
□	½" SSU1, PAT2, REL	92	165°
⊡	" " REL	4	286°
<	½" MSSW, PAT2, REL	13	165°
○	½" SSU PAT2 REL	13	165°

FITTING LEGEND

F	MEYER "FIT"
F	VICTAULIC "FIT"
M	MICHIGAN "SLIP-LOK"
P	PIPE-O-LET
SN	SHAPED NIPPLE
Z	ITT GRINNELL "EASE-TEE"
FLEX	FLEXIBLE GROOVED COUP.
VICT	VICTAULIC "MEGA-TEE"
ZF	ZERO FLEX

DISTRIBUTION

QUALITY CONTROL BY	SD DATE 1-18-89
APPROVED FOR FABRICATION BY	DATE 5/30/89
APPROVED FOR INSTALLATION BY	DATE

GENERAL NOTES

1. ALL MATERIAL AND EQUIPMENT TO BE NEW AND UNDERWRITERS APPROVED.
2. PIPING DIMENSIONS ARE CENTER TO CENTER EXCEPT RISER & DIMENSIONS SHOWN THUSLY (1-6) WHICH ARE END TO END.
3. EARTHQUAKE BRACING SHALL BE PROVIDED IN ACCORDANCE WITH NFPA PAMPHLET NO. 13-1983, SECTION 3-10.3.5.
4. PIPE HANGERS AND METHOD OF HANGING TO BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, SECTION 3-15.
5. PIPING SHALL BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, SECTION 3-1
6. JOINING OF PIPE AND FITTINGS, THREADED AND WELDED SHALL BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, SECTIONS 3-12 AND 3-13.
7. OWNER TO PROVIDE ADEQUATE HEAT TO PREVENT WATER IN PIPES FROM FREEZING IN AREAS PROTECTED BY A WET PIPE SPRINKLER SYSTEM.
8. ALL WIRING OF ELECTRICAL DEVICES (IF REQUIRED) TO BE PROVIDED BY OTHERS
9. PAINTING OF PIPE AND EQUIPMENT (IF REQUIRED) TO BE PROVIDED BY OTHERS
10. FURRING OF PIPE AND EQUIPMENT (IF REQUIRED) TO BE PROVIDED BY OTHERS

DESIGN CRITERIA AND PIPE NOTES

SPRINKLER SYSTEM HYDRAULICALLY CALCULATED TO DELIVER .21 GPM/SQ.FT. OVER 1500 SQ. FT. (ORDINARY HAZARD GP. II)

PIPE TO BE BLACK STEEL, DOMESTIC, SCH. 10 OR 40.

REVISIONS

MK	DATE	BY	
1	11-7-89	A.B.	AS-BUILT
2	8/14/90	D.W.	AS-BUILT FOR OWNERS REVIEW

CONTRACT WITH:
SAM. MECHANICAL INC.
8211 DIMOND HOOK DR.
ANCHORAGE ALASKA 99507
CONTACT: TIM JACQUES (907) 344-3200

CONTRACT NAME:
NOME HANGAR AAOF.
NOME, ALASKA

WORMALD FIRE SYSTEMS PH. (907) 563-3585
6108 PETERSBURG ST
ANCHORAGE, ALASKA 99507

DESIGNER	DATE	SHEET	JOB NO.
M. OUELLETTE	1-19-89	1 OF 3	2-0703-001

FP-1
HANGAR SPRINKLER PLAN
AS-BUILT
11-7-89

FIRST FLOOR SPRINKLER PLAN

SCALE 1/4" = 1'-0"

HYDRAULICALLY MOST DEMANDING AREA GS outlined
SYSTEM DEMAND: 43363 GPM REQUIRED AT 92.25 PSI AT BASE OF WATER TANK
@ .21 GPM OF DESIGN DENSITY OF .21 GPM OVER 1500 SQ FT
CRITERIA SOURCE: SPECIFICATIONS

AUXILLIARY REMOTE AREA #2
.16 / 1500 ft

SECOND FLOOR SPRINKLER PLAN

SCALE 1/4" = 1'-0"

"T" TRAPEZE HANGER DETAIL

SCALE: 1/2" = 1'-0"

"U" TRAPEZE HANGER DETAIL

SCALE: 1/2" = 1'-0"

PIPING SECTION

N.T.S.

FITTER/LISTER NOTES

1) ALL DROPS TO BE 1'(0-8) UNO.
2) ALL COUPLINGS TO BE FLEXIBLE UNO.
3) ALL BRANCHLINE PIPING TO BE GRINNELL "XL" THIS SHEET
4) SEND EXTRA MAT. #2
5) SEND THE FOLLOWING WALL PLATES (SIZE - QTY) (1¼" - 2), (1½" - 4), (1" - 2)

RASCO

HANGER LEGEND

A	"U" HOOK
B	COACH SCREW ROD
C	"C" CLAMP
CD	TOP BEAM CLAMP W/EXTENSION & COTTER
E	EYE ROD
F	FLUSH SHELL
G	CEILING FLANGE
H	SIDE BEAM BRACKET
J	"J" BOLT
K	SHORT CLIP W/ 2 HOLES AND U.L. LISTED BOLTING
L	"L" ROD
M	MACHINE THREADED ROD
N	TOGGLE NUT
P	POWDER DRIVEN STUD
R	WEDGE ANCHOR
S	SEE DETAIL
U	SEE DETAIL
V	
W	"U" BOLT W/(2) TOP BM. CLPS (EXTRA LONG)
X	
Y	

2 - WAY EARTHQUAKE BRACE
4 - WAY EARTHQUAKE BRACE

STRUCTURE TO CENTER LINE OF PIPE IN INCHES

SPRINKLER LEGEND

SYMB	THRDS	SPRINKLER ORIFICE SIZES AND TYPE	UPRIGHT	PENDENT	SIDEWALL	TEE SIZE
○	½"	3/16 3/8 7/16 ½ SPRAY	○	◐	◑	1/2"
○	¾"	17/32 SPRAY	□	◧	◨	3/4"
△	½"	3/8 7/16 ½ SIDEWALL	△	◭	◮	1/2"
◇	1"	1/2 DRY TYPE	◇	◈	◈	1"

TEMP. RATING	SPRINKLERS UP AND DOWN	OPENING	SYMBOL	OPENING DOWN
165°				
212°				
286°	1/2	◑	1	
350°	1	◧	1/2	
500°	1/2	◧	1/2	

SPRINKLERS USED

SYM	SPRINKLER ORIFICE SIZE, TYPE & FINISH	QUAN	TEMP
○	½" SSU., BRZ.	21	165°
○	" " "	7	212°
◎	" " "	2	286°
◉	½" SSP., BRZ. W/CHR. KIT	4	165°
◐	" " "	4	212°
◧	½", HASSW., BRZ.	2	212°
◈	½" O.P. FLUSH " BRZ.		
	CENTRAL "A" A-15	5	165°
	TOTAL	43	

FITTING LEGEND

C	MEYERTECH
F	VICTAULIC "FIT"
M	MICHIGAN "SLIP-LOK"
*PI	PIPE-O-LET
SN	SHAPED NIPPLE
Z	ITT GRINNELL "EASE-TEE"
ZF	ZERAD FLEX

APPROVALS REQUIRED

OWNER / ARCH.
I.S.O.
STATE FIRE MARSHALL

DISTRIBUTION

QUALITY CONTROL BY SD DATE 1-18-89
APPROVED FOR FABRICATION BY [signature] DATE 3/30/89
APPROVED FOR INSTALLATION BY DATE

GENERAL NOTES

1. ALL MATERIAL AND EQUIPMENT TO BE NEW AND UNDERWRITERS APPROVED.
2. PIPING DIMENSIONS ARE CENTER TO CENTER EXCEPT RISER & DIMENSIONS SHOWN, THUSLY (1-6) WHICH ARE END TO END.
3. EARTHQUAKE BRACING SHALL BE PROVIDED IN ACCORDANCE WITH NFPA PAMPHLET NO. 13-1983, SECTION 3-10.3.5.
4. PIPE HANGERS AND METHOD OF HANGING TO BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, SECTION 3-15.
5. PIPING SHALL BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, SECTION 3-1.
6. JOINING OF PIPE AND FITTINGS, THREADED AND WELDED SHALL BE IN ACCORDANCE WITH NFPA PAMPHLET NO. 13, SECTIONS 3-12 AND 3-13.
7. OWNER TO PROVIDE ADEQUATE HEAT TO PREVENT WATER IN PIPES FROM FREEZING IN AREAS PROTECTED BY A WET PIPE SPRINKLER SYSTEM.
8. ALL WIRING OF ELECTRICAL DEVICES (IF REQUIRED) TO BE PROVIDED BY OTHERS
9. PAINTING OF PIPE AND EQUIPMENT (IF REQUIRED) TO BE PROVIDED BY OTHERS
10. FURRING OF PIPE AND EQUIPMENT (IF REQUIRED) TO BE PROVIDED BY OTHERS

DESIGN CRITERIA AND PIPE NOTES

SPRINKLER SYSTEM HYDRAULICALLY CALCULATED TO DELIVER .21 GPM/SQ.FT. FOR 1500 ft. (ORDINARY HAZARD GP. III).
FOR OFFICE AREA .16 GPM/SQ.FT FOR 1500 ft. (ORDINARY HAZARD GP. I)
PIPE TO BE BLACK STEEL, DOMESTIC SCH. 10 OR 40.

REVISIONS			
MK	DATE	BY	
1	11-7-89	AB	AS-BUILT
2	8/16/90	DEW	AS-BUILT PER OWNERS REVIEW


CONTRACT WITH:
S.A.J. MECHANICAL INC.
8211 DIMOND HOOK DR.
ANCHORAGE, ALASKA 99507
CONTACT: TIM JACQUES (907) 344-3200

CONTRACT NAME:
NOME HANGAR AAOF
NOME, ALASKA

WORMALD FIRE SYSTEMS
6100 PETERSBURG ST.
ANCHORAGE ALASKA 99507
PH. (907) 563-3585

DESIGNER	DATE	SHEET	JOB NO.

FP-2
AS-BUILT 2ND FLOOR SPRINKLER PLAN
11-7-89


11'-0"
45"
62"
6"
WALL PENTRATION BY OTHERS
FIRE DEPT. CONNECTION
WATER MOTOR GONG ABOVE
8" UP SEE DETAIL
4" GALV.
DUCT
1" GALV.
1/4" GALV.
7'-6" AFF
6" GALV.
6" GALV.
6" GALV.