

DEPARTMENT OF HEALTH AND SOCIAL SERVICES  
ANCHORAGE PIONEER HOME – PHARMACY RELOCATION  
ANCHORAGE, AK

**October 30, 2018**

**ADDENDUM NO. 5**

TO: ALL PLAN HOLDERS

FROM: Mark Moon, DHSS Project Manager

SUBJECT: Extend Bid Deadline and CCTV Design Changes  
Project # AJF 19-03C

---

This addendum consists of:

1. Bid Due Date Extension
2. CCTV Design Changes

Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

**Note to Bidders:** Bidders are required to acknowledge this addendum on the proposal form. The following additions, corrections, and changes are hereby made to the subject invitation to bid.

**Notes:**

- **Bid due date has been extended from October 31, 2018 to 2:00pm November 6, 2018**

Project related questions or clarifications: Mark Moon, DHSS Project Manager at (907) 269-7812 or [mark.moon@alaska.gov](mailto:mark.moon@alaska.gov).

Issued by: Mark Moon, DHSS Project Manager

Issue Date: October 30, 2018

ATTACHMENTS: CCTV RE-DESIGN DOCUMENT

**Stantec Architecture Inc.**  
725 East Fireweed Lane Suite 200, Anchorage AK 99503-2245  
Phone: (907) 276-4245  
Fax: (907) 258-4653

## Anchorage Pioneer Home Pharmacy Relocation #AJF 19-03C

October 30, 2018

BIDDER QUESTION	DESIGNER COMMENT	DOCUMENT REFERENCE
Existing CCTV system not adequate for adding three new cameras	<ul style="list-style-type: none"><li>Provide new CCTV system with three cameras and DVR. CCTV system design based on DVR model Avigilon HD Video Appliance VMA-AS2-8P4 <b>or equal</b> and cameras model Avigilon H4SL-D 3.0 MP with in-ceiling mount <b>or equal</b>.</li></ul> <p><u>On E-102 Addendum 2:</u></p> <ul style="list-style-type: none"><li>Delete new 8-port POE network switch located northeast corner of room 301 and replace with new DVR.</li><li>Delete sheet note 14.</li><li>Revise sheet note 17: Provide surface raceway with Cat5e cables, route along ceiling and connect with Wiremold 4000 system. Use Wiremold 4000 to route camera Cat5e cables to new DVR located in northeast corner of room 301.</li><li>Delete sheet note 18.</li><li>Add General Note 8: Existing access control panels (S2 Netbox and S2 Netbox Extreme) and card reader located in basement Pharmacy to be removed and turned over to owner.</li></ul>	E-102 (Addendum 2)