



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

Department of Corrections
DIVISION OF ADMINISTRATIVE SERVICES
Anchorage Procurement Section

550 W. 7th Avenue, Suite 1800
Anchorage, AK 99501-3569
Tele: 907.269.7344
Fax: 907.269.7345
Email: gary.bailey@alaska.gov

February 15, 2019

ATTN: All Bidders

RE: ITB # 190004524 - Roof Replacement - SCCC

Addendum #3

The purpose of this addendum is to provide additional information per the Architect as follows;

1. "At openings less than 16" x 16", provide a flat sheet of 16 GA sheet metal with edges extending 6" beyond the opening at all sides and attach to the existing metal deck with #8 screws at 6" on center around perimeter."
2. "For openings larger than 16" x 16", provide metal roof decking that can span from structural support beam to beam that will nest within the deck profile and attached to the existing decking with #8 screws at 12" on center at perimeter of opening in the existing deck."
3. Provide fire proofing at new deck infills and where disturbed during construction activities.

End of Addendum #3

Sincerely,

A handwritten signature in black ink, appearing to read "Gary Bailey".

Gary Bailey
Procurement Officer