



THE STATE  
of **ALASKA**  
GOVERNOR MIKE DUNLEAVY

**Department of Corrections**  
**DIVISION OF ADMINISTRATIVE SERVICES**  
Anchorage Procurement Section

550 W. 7<sup>th</sup> Avenue, Suite 1800  
Anchorage, AK 99501-3569  
Tele: 907.269.7344  
Fax: 907.269.7345  
Email: [gary.bailey@alaska.gov](mailto:gary.bailey@alaska.gov)

February 22, 2019

ATTN: All Bidders

RE: ITB # 190004524 - Roof Replacement - SCCC

**Addendum #5**

The purpose of this addendum is to provide answer to question as follows;

**Q - Regarding Spec. Section 75300, 3.05 Insulation:**

There are two Board Insulation Products specified with different R Values per Inch. The plans only indicate an insulation thickness as far as I have found, which would give you a different R Value depending upon the insulation used. Please indicate the desired R Value to better evaluate the best value product to be used.

**A – For where 5” thick rigid insulation is called out, the minimum R-value should be 21.75 @ 75 degrees F.**

**For where 8” thick rigid insulation is called out, the minimum R-value should be 34.8 @ 75 degrees F.**

**End of Addendum #5**

Sincerely,

A handwritten signature in black ink, appearing to read "Gary Bailey".

Gary Bailey  
Procurement Officer