



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

Department of Corrections
DIVISION OF ADMINISTRATIVE SERVICES
Anchorage Procurement Section

550 W. 7th Avenue, Suite 1800
Anchorage, AK 99501-3569
Tele: 907.269.7344
Fax: 907.269.7345
Email: gary.bailey@alaska.gov

February 26, 2019

ATTN: All Bidders

RE: ITB # 190004524 - Roof Replacement - SCCC

Addendum # 7

The purpose of this addendum is to answer a question that was received.

Q - RE: Roof Accessories 2.04 Snow Guards 4 a.

Is the intent to use S-5-KHD with inserts first row and use same clamp no inserts other 9 rows. The concern is there is a huge deference in holding strength pounds per square foot without inserts that are installed in new construction. Are clamps to be installed on each rib and designed for Seward snow fall?

A - The intent as specified for the snow guard system, is that the first row is to have S-5-KHD clamps and inserts and all subsequent rows shall have clamps as required by the manufacturer to meet the snow load requirements for Seward, Alaska.

End of Addendum # 7

Sincerely,

A handwritten signature in cursive script that reads "Gary Bailey".

Gary Bailey
Procurement Officer