



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

Department of Corrections
DIVISION OF ADMINISTRATIVE SERVICES
Anchorage Procurement Office

550 W. 7th Ave., Suite 1800
Anchorage, Alaska 99501-3569
Main: 907.269-7349
Fax: 907.269-7345
Email: evan.patterson@alaska.gov

Issue Date: May 30, 2019

ATTN: Vendors

RE: Project Name: HMCC Roof Repairs
Project Number: 2019-2102-0101
Project Location: Hiland Mountain Correctional Center
ITB Opening Date and Time: June 3, 2019 @ 2:00 PM local time

Addendum # SIX (6)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following changes are required:

1. The bid date will be extended from May 31 to June 3rd, 2019 @ 2:00 PM local time.

The following are questions from interested parties and the department's response:

1. Question: Requesting approval of the GAF Roof System (GAF Timberline Ultra HD Shingles) for the Hiland Mountain Correction Center project. GAF Enhanced System Plus Warranty Coverage installed by GAF Factory Certified Contractor. Holds a 40 year warranty term with upfront 20 year non-prorated coverage then prorates from year 20 through year 40. (Please see warranty for more detail).

Answer: Shingles must be SBS-modified asphalt shingles. See addendum #2 Asphalt Shingle specification 07 31 13.

Section 07 311 13 – Asphalt Shingles that was included in addendum #2 and changed in addendum #4; change paragraph 1.10, A, 2 as follows:

2. Material Warranty Period: 40 years from date of Substantial Completion.

The department is not accepting further questions.

End of Addendum #6

Please be reminded that all addendums must be acknowledged on your bid proposal.

Sincerely,

A handwritten signature in blue ink, appearing to be "SA".

Evan Patterson
Procurement Officer

cc: Ryan Henderson, Project Manager, DOC
Dan Aicher, Facilities Manager, DOC