

STATE OF ALASKA ITB NUMBER ITB 2520C003
AMENDMENT NUMBER ONE (1)



Department of Transportation &
Public Facilities
Division of Supply and Services
2200 E. 42nd Avenue, Room 110
Anchorage, AK 99508

THIS IS NOT AN ORDER

DATE AMENDMENT ISSUED: June 26, 2019

ITB TITLE: TSAIA Fire Pit Water Removal

ITB OPENING DATE AND TIME: June 27, 2019 AT 10:00 AM

MANDATORY RETURN AMENDMENT

This Amendment Serves To: Change the required by completion date and answer question(s) from potential bidders while providing additional Specification/Scope of Work information. Updated Bid Schedule attached to be used for submitted bids.

QUESTION: Would the state consider a later date for the Guaranteed Completed by date?

ANSWER: YES, a later date would be acceptable but no later than **September 13, 2019**. We will not be able to extend beyond that date.

QUESTION: "If you already have badging from the airport, do you need to be escorted still"?

ANSWER: No. If you have badging/access to the airport you will only be required to attend morning meetings prior to entering airport property at the beginning of each day. This will be coordinated and agreed upon by Scott Lytle.

QUESTION: "Is there a specific QTY of removal you want us to consider or do you want water removed to a certain water level"?

ANSWER: The airport would like as much water removed as possible- which at this time is unknown. We will need to know Bid Unit cost to make this determination.

QUESTION: "Is there onsite discharge allowed"?

ANSWER: No.

QUESTION: "Does the tin (corrugated tubes/piping) stay in the pit?

ANSWER: Yes.

QUESTION: "Can boiler equipment be used on site"?

ANSWER: Yes.

STATE OF ALASKA ITB NUMBER ITB 2520C003
AMENDMENT NUMBER ONE (1)

Specifications/Scope of Work additions:

- *Water can be pumped from the weir and a small auxiliary water pond nearby.
- *There is no electricity onsite.
- *Water Pond is lined.
- *Contracted party is expected to report any animals (alive or dead) to the project manager, Scott Lytle.
- *As Builds will be provided upon request that will include Fuel Piping in Area.
- *There is only 1 weir.
- *Water can be drained to a smaller lined pit if needed but that pit will need to be drained as well.
- *Equipment can be stored on site during work to remove the water but only during the agreed upon schedule. No permanent equipment storage will be allowed.
- *Parking is available for contractor vehicle(s) prior to entering airport grounds.
- *Airport personnel can escort up to 2 vehicles at a time. More than two vehicles will require additional airport personnel.
- *Use of boiler or other fuel burning equipment is allowed. However, if the steam plump and/or exhaust plump interferes with aircraft operations, operations must cease immediately. Airport Ops or ANC will be the sole determiner of interference with aircraft operations.

BID SCHEDULE

ITEM NO.	EST QTY.	UNIT	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.	40,000	GALLONS	Water Removal and Disposal	\$_____	\$_____

Guaranteed to be completed by: **September 13, 2019.**

ORDERING ADDRESS: _____

Contact: _____

Phone: _____

THIS IS A MANDATORY RETURN AMENDMENT

YOUR BID MAY BE CONSIDERED NON-RESPONSIVE IF THIS SIGNED AMENDMENT IS NOT RECEIVED WITH YOUR BID.

NAME OF COMPANY

SIGNATURE

DATE

Frank Coppa
Procurement Officer
PHONE: (907) 269-0858
FAX: (907) 269-0872