



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501
Phone 907-265-2355
Fax 907-265-2439
BatesT@akrr.com

October 3, 2019

Addendum Number 2
Invitation to Bid 19-36-207551
Potter Hill Earthquake Damage Repair & Restoration

This addendum is being issued to provide information as follows: : THE CLOSING DATE FOR THIS SOLICITATION HAS CHANGED AS FOLLOWS, SEALED BIDS WILL BE RECEIVED AT RECEPTIONS, ALASKA RAILROAD CORP. 327 W. SHIP CREEK AVENUE, ANCHORAGE AK 99501 UNTIL 3:00 PM LOCAL TIME ON, **OCTOBER 4, 2019 AT WHICH TIME BIDS WILL BE PUBLICLY OPENED.**

MODIFICATION - APPENDIX J: COST SCHEDULE

Remove Appendix J: Cost Schedule, in its entirety, and replace with the attached revised cost schedule.

BIDDER QUESTIONS:

1. Pay item 605 includes the geotextile now specifically called out on the revised drawing sheet 2 of 12. Both the specifications and addendum questions 2, 21, & 24 ask for clarification as to the specific location of the Geogrid and Geoweb. Since they are not apparent on the drawings, then please confirm that they are not required for this project at any location. If they are, please indicate where they are specifically located at.

Not Required.

2. Pay item quantities 603, 611 for the 12", 18" and 24" CMP do not match to the corresponding estimated quantities on sheet 2 of 12. If the pay item quantity is correct, exactly where are all the pay item quantities located on the drawings?

The estimated quantities for CMP.

12" CMP 220'

18" CMP 60'

24" CMP 60'

This pipe shall be 12 gage.

Please see section 10.9 of the Construction General Contract

3. Pay item quantities 603, 611 for the 12", 18" and 24" CMP list flume. Is the flume the same as originally built (the ½ round culvert shown on original drawing 4, Drainage) or the Angular Rock flumes shown on the current drawings?

Angular Rock flumes as shown on current drawings.

4. Is geotextile required under the Angular Rock flumes and if so, specifically which geotextile specification is to be used?

Yes, Woven geotextile

ATTACHMENTS:

- 2nd Revised Appendix J: Cost Schedule (3 pages)

Please acknowledge receipt of this and all addendums in your firm's **Construction Bid Form (Form 395-0121)**. **All other dates, terms and conditions remain unchanged.**

Please direct all responses and/or questions concerning this solicitation to Timothy Bates, Alaska Railroad Corporation, Contracts, 327 Ship Creek Avenue, Second Floor, Anchorage, AK 99501, telephone number 907-265-2355, fax number 907-265-2439 or at email address BatesT@akrr.com .

Sincerely,

Timothy Bates

Timothy Bates

Contract Administrator

Alaska Railroad Corporation