



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

Department of Corrections
DIVISION OF ADMINISTRATIVE SERVICES
Anchorage Procurement Office

550 W. 7th Ave., Suite 1800
Anchorage, Alaska 99501-3569
Main: 907.269.7344
Fax: 907.269-7345
Email: gary.bailey@alaska.gov

January 30, 2020

ATTN: All Vendors

RE: Project Name: Laundry Expansion
Project Number: 200003569A
Project Location: Lemon Creek Correctional Center
ITB Opening Date and Time: February 5, 2020 @ 2:00 PM local time

Addendum # FOUR (4)

This addendum forms a part of the ITB documents. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

ISSUE:

Addendum #3 – issued on 1/29/2020, Question #2 and Response stated:

2. Can washer drains be routed around the washer to drain if center drain is not available?

RESPONSE: No, the DOC requires the center drain type washers due to space constraints and potential added work activities and concerns with rerouting non-center drain washers.

CHANGE:

RESPONSE has been modified on Questions #2 to state:

The DOC will accept rear discharge type washers, if they are positioned to span the center of the drain trough and all connections/hoses are securely and professionally routed alongside the unit as it feeds into the drain trough.

End of Addendum # 4

Sincerely,

A handwritten signature in black ink that reads "Gary Bailey".

Gary Bailey
Procurement Officer