

PLUMBING FIXTURE SCHEDULE

EQ. ID	DESCRIPTION	SERVICE CONNECTIONS (INCH)				BASIS OF DESIGN: PRIMARY FIXTURE		COMMENT(S)
		CW	HW	W	V	MANUFACTURER	MODEL	
P-1(R)	EXISTING WALL HUNG FLUSH TANK WATER CLOSET	1/2"		4"	2"	EXISTING		EXISTING WALL-HUNG FLUSH TANK WATER CLOSET. CONTRACTOR TO REMOVE CLOSET AND COORDINATE WITH THE OWNER FOR TEMPORARY DURING RENOVATION. REINSTALL WATER CLOSET WITH NEW SEAT, GASKETS, AND FLUSH KIT.
P-2(N)	LAVATORY, COUNTER, ADA COMPLIANT	1/2"	1/2"	2"	1-1/2"	CORIAN/KOHLER	816P SINK/PURIST K-14407-3 SINK FAUCET	
P-3(N)	KITCHEN SINK, ADA COMPLIANT	1/2"	1/2"	2"	2"	SEE ARCHITECTURAL		
P-4(N)	SHOWER, ADA COMPLIANT	1/2"	1/2"			KOHLER	PURIST SERIES K-22178-G MULTI-FUNCTION SHOWER VALVE KIT, PRESSURE BALANCED SHOWER VALVE, PURIST SHOWER VALVE TRIM KIT, AND CLEARFLO SQUARE SHOWER DRAIN.	
P-5(N)	RECLINING BATHING SYSTEM					ARJO	PARKER SERIES	PROVIDE FLEXIBLE CONNECTIONS BETWEEN BATH UNIT AND SUPPLY AND DRAIN WALL BOXES.
P-6(E)	HANDWASH SINK, ADA COMPLIANT	1/2"	1/2"	2"	1-1/2"	EXISTING		EXISTING FIXTURE TO REMAIN EXCEPT WHERE DELETED FROM THE PROJECT.
CW-1(N)	CLOTHES WASHER OUTLET BOX					IPS CORP.	CENTER DRAIN SERIES OUTLET BOX	
OB-1(N)	BATHING UNIT SUPPLY WALL BOX	1/2"	1/2"			IPS CORP.	MULTIBOX ANGLE STOP BOX SERIES OR EQUAL	
OB-2(N)	BATHING UNIT DRAIN WALL BOX			2"	2"	IPS CORP.	MULTIBOX OUTLET BOX OR EQUAL	
FD-1(N)	FLOOR DRAIN, SHOWER			2"	1-1/2"	KOHLER	CLEARFLO SQUARE SHOWER DRAIN.	COORDINATE WITH FIXTURE P-4(N)

AIR TERMINAL SCHEDULE

EQ. ID	DESCRIPTION	TERMINAL TYPE		AIR SIDE PERFORMANCE			BASIS OF DESIGN		COMMENT(S)
		FACE SIZE (INCH)	NECK SIZE	AIRFLOW (CFM)	ESP (IN. W.C.)	NOISE	MANUFACTURER	MODEL	
EA-1(N)	DRYER EXHAUST VENT		4"				SEIHO	SFB SERIES	CUSTOM COLOR. COORDINATE WITH OWNER FOR COLOR SELECTION.
EA-2(N)	KITCHEN HOOD EXHAUST VENT		8"				SEIHO	SFX SERIES	CUSTOM COLOR. COORDINATE WITH OWNER FOR COLOR SELECTION.
SA-1(N)	SQAURE FACE DIFFUSER W/ROUND NECK CONNECTION	24"X24"	8"	60 CFM	0.01 in-wg	<19	PRICE INDUSTRIES	SPD SERIES	

MISCELLANEOUS MECHANICAL EQUIPMENT SCHEDULE

EQ. ID	DESCRIPTION	ELECTRICAL	BASIS OF DESIGN		ACCESSORIES	COMMENT(S)
			MANUFACTURER	MODEL		
AD-1(N)	1-HR RATED ACCESS DOOR		(SEE ARCHITECTURAL)			
FSD-1(N)	COMBINATION FIRE AND SMOKE DAMPER	(SEE NOTE)	RUSKIN	FSD35 8"X6"		COORDINATE WITH ELECTRICAL FOR ACTUATION AND POWER INTERFACE WITH BUILDING FIRE ALARM SYSTEM
FSD-2(N)	COMBINATION FIRE AND SMOKE DAMPER	(SEE NOTE)	RUSKIN	FSD35G 24"X24"		COORDINATE WITH ELECTRICAL FOR ACTUATION AND POWER INTERFACE WITH BUILDING FIRE ALARM SYSTEM
FSD-3(N)	COMBINATION FIRE AND SMOKE DAMPER	(SEE NOTE)	RUSKIN	FSD35G 20"X16"		COORDINATE WITH ELECTRICAL FOR ACTUATION AND POWER INTERFACE WITH BUILDING FIRE ALARM SYSTEM
HD-1(N)	RANGE HOOD WITH INTEGRAL FAN AND FIRE SUPPRESSION SYSTEM. INTEGRAL FAN. REAR DISCHARGE	1.2 AMP, 115V/1PH	GREENHECK	GRRS-W-30-R-E-X	SELF-CONTAINED FIRE SUPPRESSION SYSTEM WITH ELECTRONIC DETECTION AND MANUAL PULL STATION AND REMOTE HORN STROBE. REMOTE USER INTERFACE (ADA COMPLIANT).	ARRANGE 4" STAND-OFF FROM WALL FOR REAR DISCHARGE DUCT TRANSITON AS APPROPRIATE. COORDINATE WITH OWNER FOR MOIUNTING OF USER INTERFACE, PULL STATION, AND HORN STROBE. COORDINATE WITH ELECTRICAL FOR SUPERVISED SHUT-OFF/TIMER CONTROL AT NURSE STATION AS APPLICABLE..



Steve Fishback Architect
3720 Bellanca Way, Unit B, Anchorage, AK 99502
P: (907) 375-5584 E: Steve@fishbackak.com

ANCHORAGE PIONEER HOME
4TH FLOOR TENANT IMPROVEMENT
923 W 11TH AVE, ANCHORAGE AK 99501

Revisions:	
2	- 2/13/2020
Drawn By:	Checked By:
JTC	JTC
Date:	
1/9/2020	
Phase:	
MOA PLAN REVIEW	
Job No:	
SHEET TITLE:	
MECHANICAL EQUIPMENT SCHEDULES	
SHEET NO:	

M1.2