



State of Alaska
Department of Environmental Conservation
Village Safe Water Program

555 Cordova Street
Anchorage, AK 99501
Evan.patterson@alaska.gov

May 18, 2021

To: Vendor List

Re: Amendment 2
ITB 21-VSW-VOZ-024
Falls Creek Water Service Extension
Voznesenka, Alaska
ITB Due Date: May 19, 2021 @ 2:00 PM AST

The following are questions from interested parties and the department's response.

1. Vendor: Water system. For the bolt for flanges on spec 33 1 416 2.03 A. 7. – States “carbon steel or stainless steel”. There is a decent price range between the two materials. Which one do you want for the project?

Department: Both materials are acceptable for the project as laid out in the specifications, it is up to the bidder to make the choice whether to use stainless steel or carbon steel.

2. Vendor: Septic system. For the septic tanks on spec 33 34 13 2.01 A – Can we substitute a Infiltrator septic tank either the 1060g or 1530g to meet the 1250g in the spec?

Department: Septic tanks are not part of the scope of this ITB. Per the ITB “References in the drawings and specifications to wastewater are not within the scope of this ITB.”

3. Vendor: I am looking for Bid Form 25D-9S for the above mention project. I am not finding it in the package. Can you advise?

Department: The “S” is a typo in division 00120 Required Documents, #1 Bid Form (Form 25D-**S**). It is Bid Proposal 25D-9**A**, division 00310.

4. Vendor: With regards to septic systems should there be a separate line item? If not, what pay item should it be included on?

Department: Please see above question / response # 2.

Evan Patterson

Procurement Specialist