

**DEPARTMENT OF HEALTH AND SOCIAL SERVICES  
FAIRBANKS PIONEER HOME – SPRINKLER UPGRADES  
FAIRBANKS, AK**

**August 18, 2021**

**ADDENDUM NO. 1**

TO: ALL PLAN HOLDERS

FROM: Chris Capps, DHSS Project Manager

SUBJECT: Sprinkler isolation valve and tamper switch  
Project # ANC 22-06C

---

Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

**Note to Bidders:** Bidders are required to acknowledge this addendum on the proposal form. The following additions, corrections, and changes are hereby made to the subject invitation to bid.

This addendum consists of two items:

1. A new sprinkler isolation valve is required to shut off water to the sprinkler system while maintaining service to the domestic water.
2. Install a tamper switch on the new isolation valve tied into the fire alarm panel so that it cannot be shut off by accident without setting off an alarm.

**Notes:**

- **Bid due date and time of 2:00pm September 14, 2021, remains unchanged**

Project related questions or clarifications: Chris Capps, DHSS Project Manager at (907) 269-7816 or [chris.capps@alaska.gov](mailto:chris.capps@alaska.gov)

Issued by: Chris Capps, DHSS Project Manager  
Issue Date: August 18, 2021

**END OF ADDENDUM**