



**State of Alaska**  
**Department of Environmental Conservation**  
**Village Safe Water Program**

555 Cordova Street  
Anchorage, AK 99501  
[Evan.patterson@alaska.gov](mailto:Evan.patterson@alaska.gov)

December 3, 2021

To: Vendor List

Re: Amendment 3  
ITB 22-VSW-TLT-032  
Packaged Water Treatment System  
ITB Due Date: December 8, 2021 @ 10:00 AM AST

**The following changes are required:**

1. The ITB due date is extended from December 6, 2021 to December 8, 2021 @ 10:00 AM AST.

**The following are vendor questions and the department's response:**

1. Vendor: As discussed, the supply of equipment on the subject ITB is a bit confusing. It appears the filter system is a prepackaged system but it is not extremely clear on the Chemical feed equipment. The drawings show all that equipment to be part of the package WTP equipment but not clear if this is to be purchased as a pre-packaged system, if the contractor will be installing or if the equipment is to be shipped individually to the modular building manufacturer in Anchorage for installation. If that is the case, is the owner actually purchasing that equipment?

Department: Revise and add 46 07 13, Paragraph 1.1 C.: "It is the intent of this specification that a complete, pre-fabricated, packaged water treatment system AND ANCILLARY EQUIPMENT LISTED IN THIS SPECIFICATION be supplied by a single supplier and that it shall include, but not be limited to, the following components, designated with an \* on the Drawings."

2. Vendor: There are 2 lift station pumps called out on the pump schedule but there are no specifications or drawings included to determine how they are installed. Are they being installed in an existing sump or is there a package required with basin, floats, controls, etc?

Department: This work is not included in the ITB, 46 07 13, Paragraph 1.1 A. details that the section is for packaged water treatment plant equipment, consistent with the ITB. The Drawing status indicates WTP Equipment Procurement. The balance of the project will be bid at a later date.

Add new Paragraph to 46 07 13, Paragraph 1.1 F.5.: "Wastewater sump, lift station, and associated components."

**Bidders must acknowledge this amendment on Submittal Form A – Bidder Information. A bid that doesn't acknowledge this amendment may be found non-responsive and rejected.**

Evan Patterson



Procurement Specialist