

## ADDENDUM #2

### PALMER COURTHOUSE BOILER ROOM UPGRADES & BOILER REPLACEMENT PROJECT #PAL-C-21-0010

Date: December 20, 2021

To All Plan Holders:

The following changes, additions, clarifications, and/or deletions are hereby made a part of the Contract Documents for the above noted project, fully and completely as if the same were fully contained therein. All other terms, conditions, and specifications of the original Invitation to Bid remain unchanged.

**This amendment must be acknowledged in the space provided on the Bid Schedule.**

The Submittal Date and Time is HEARBY EXTENDED. TO: January 11, 2022 at 10:00 a.m.

The modifications directed by this Addendum #2 are described on this page and the following attachments:

- |                   |        |
|-------------------|--------|
| 1. Addendum Text: | 1 page |
| 2. Attachment     | NONE   |

#### CHANGES TO ADDENDA

1. None.

#### CHANGES TO SPECIFICATIONS

##### **Page 27 The Hydronic Piping Specification, Section 23 21 23**

1.
  - a. Section 23 21 23, allows copper pipe with either wrought copper or press fittings. The schematics on M203 and M204 show multiple locations in the new 3" and 4" heating lines where there are gauges, thermometers, sensors, etc. installed.

The ACS will Allow the limited use of an Extruded "T-Drill" with a brazed joint at these locations.

2. THE CONDITION OF THE FOREGOING OBLIGATION is that the principal has submitted the accompanying bid or proposal in writing, date as shown above, on **Palmer Courthouse Boiler Room Upgrades & Replacement, Project #PAL-C-21-0010.**

**END OF ADDENDUM #2**