

STATE OF ALASKA

DEPARTMENT OF NATURAL RESOURCES
DIVISION OF SUPPORT SERVICES



INVITATION TO BID (ITB) 10-025-22

Tip Levarg Road Construction

Addendum Five

Date of Issue: March 7, 2022

Addendum Five serves to answer questions from vendors and provide information on conditional land use permits as required by the Kenai Peninsula Borough.

Important Note to Offerors: You must sign and return this page of the addendum document with your bid. Failure to do so will result in the rejection of your bid. Only the ITB terms and conditions referenced in this addendum are being changed. All other terms and conditions of the ITB remain the same. This Addendum Five is hereby made part of the ITB and is a total of two pages.

Chris Brooks

Procurement Specialist

Phone: (907) 269-8666

Email: christopher.brooks@alaska.gov

COMPANY SUBMITTING BID

AUTHORIZED SIGNATURE

DATE

Questions from Vendors

Question 1: *KPB Road Construction Standards 14.06.090 includes a table of roadway widths given road category.*

Category I roads are to be minimum 20' top width, maximum 28'.

Category II roads are 22-28'

Category III roads are 24-28/

Given these ranges, what is required of the Contractor under this project? If nothing is specified, we will assume the minimum width is acceptable.

Answer: The minimum width required under the specified category is acceptable.

End of Addendum Five