

STATE OF ALASKA

DEPARTMENT OF NATURAL RESOURCES
DIVISION OF FORESTRY



REQUEST FOR QUOTES (RFQ) 10-029-22

NORTH THORNE BAY GATE FABRICATION

Amendment 2

Date of Issue: March 18, 2022

Amendment 2 serves to answer questions and change RFQ

Important Note to Offerors: You must sign and return this page of the amendment document with your quote. Failure to do so will result in the rejection of your quote. Only the RFQ terms and conditions referenced in this amendment are being changed. All other terms and conditions of the RFQ remain the same. This Amendment 2 is hereby made part of the RFQ and is a total of 2 pages.

Michael Burkhead
Procurement Specialist
Phone: (907) 269-8461
Email: michael.burkhead@alaska.gov

COMPANY SUBMITTING QUOTE

AUTHORIZED SIGNATURE

DATE

Responses to Questions Received by Offerors

Question 1: In regards to the Thorne Bay Gate Fabrication it says "To Be Painted Yellow"

Is there any standard for steel prep prior to painting, i.e. SSPC-SP6 Commercial dry abrasive blast or is painting over the mil scale steel acceptable?

Is there a type of paint expected to be used? i.e. epoxy/polyurethane, industrial enamel, polysiloxane?

Answer: Specification of Finish to conform to State Standard Specifications for Highway Construction, 2017 Edition, Sect 5.04 Steel Structures, 5.03-303 Painting. And Section 7.08-2.01 Paint. See Changes to RFQ below for links and details.

Changes to the RFQ

Change 1: Specification of Finish.

Finish of the gate shall be as Department approved in submitted shop drawings prior to fabrication per:

State Standard Specifications for Highway Construction 2017 edition available for download at:

<https://dot.alaska.gov/stwddes/dcspecs/assets/pdf/hwyspecs/sshc2017.pdf>

Applicable Sections:

Section 5.04 Steel Structures

5.04-3.03 Painting

Section 7.08-2.01 Paint

No further changes to RFQ

End of Amendment 2