



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Military and
Veterans Affairs**

FMO Design and Construction

57024 Roosevelt Rd

PO Box 5169

JBER, AK 99505

Email: jay.friesen@alaska.gov

Issue Date: June 30, 2022

ATTN: Vendors

RE: Project Name: Sitka Armory Emergency Backup Generator
Project Number: 02D2420028
Project Location: Sitka, Alaska

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. Delete original Bid Due Date of July 27, 2022 at 2:00 PM Replace with **August 8, 2022 at 2:00PM**
2. There will be an optional site visit at the Sitka Armory on Tuesday July, 26, 2022 at 1:00 PM.
3. The specifications call for a single phase transfer switch. In reality, a three phase switch is needed.

This addendum is considered part of the Request for Proposal (RFP) and is to be acknowledge on your bid proposal.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

End of Addendum