



THE STATE  
of **ALASKA**  
GOVERNOR MIKE DUNLEAVY

**Department of Military and  
Veterans Affairs**

**FMO Design and Construction**

57024 Roosevelt Rd

PO Box 5169

JBER, AK 99505

Email: [jay.friesen@alaska.gov](mailto:jay.friesen@alaska.gov)

Issue Date: July 20, 2022

ATTN: Vendors

**RE:**      **Project Name:**                      Valdez Armory Emergency Backup Generator  
             **Project Number:**                02D8020026  
             **Project Location:**              Valdez, Alaska

**Addendum # Four (4)**

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. The Bids Due Date for the Valdez Armory Emergency Backup Generator project has been extended to August 1, 2022 at 2:00.
2. There will be a minimum of four 6" bollards placed on the side and in front of the generator to avoid the possibility of a vehicle or snowplow damaging the generator. The bollards will be embedded in concrete a minimum of four feet below grade with four feet above grade. The bollards shall be hazard yellow in color.

This addendum is considered part of the Request for Proposal (RFP) and is to be acknowledge on your bid proposal.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

End of Addendum