



THE STATE  
of **ALASKA**  
GOVERNOR MIKE DUNLEAVY

**Department of Military and  
Veterans Affairs**

**FMO Design and Construction**

57024 Roosevelt Rd

PO Box 5169

JBER, AK 99505

Email: [jay.friesen@alaska.gov](mailto:jay.friesen@alaska.gov)

Issue Date: July 21, 2022

ATTN: Vendors

**RE:**      **Project Name:**                      Kotzebue Armory Emergency Backup Generator  
             **Project Number:**                02C0122010  
             **Project Location:**              Kotzebue, Alaska

**Addendum # Two (2)**

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. Due to a conflict with the ventilation system in the Armory, the generator site will be moved approximately 60' away from the building. (There will be a drawing attached to this addendum.)
2. Provide a new 800 Amp Service Disconnect on the exterior of the building.
3. Install three bollards in front of the generator to protect from vehicle damage. The bollards will be minimum of 6" in diameter, minimum four feet below grade and four feet above grade and hazard yellow in color.
4. The current bids due date of July 25, 2022 will be extended to August 8, 2022 at 2:00 PM.

This addendum is considered part of the Request for Proposal (RFP) and is to be acknowledge on your bid proposal.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

