



Issue Date: July 27, 2022

ATTN: Vendors

RE: **Project Name:** Valdez Armory Emergency Backup Generator
 Project Number: 02D8020026
 Project Location: Valdez, Alaska

Addendum # Five (5)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. It has been determined that the General Requirements Part 1.02 C-2 that states the Generator size to be based on full load potential plus 25% be changed to read: "The Generator needs to be capable of the constant load of 50% load potential of the building." Therefore, we are waiving Part 3-1 & 2 of the General Requirements attached to the original offering.
2. The deadline for questions on this project is Tuesday August 2, 2022.
3. The bids due date has been changed to August 8, 2022 at 2:00 PM.
4. In the quote section of Form SPC-002 the contractor must provide specifications for the generator, panels and associated switches etc. to verify that it meets the specifications in the General Requirements and subsequent addenda.

This addendum is considered part of the Request for Proposal (RFP) and is to be acknowledge on your bid proposal.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198