



THE STATE  
of **ALASKA**  
GOVERNOR MIKE DUNLEAVY

**Department of Military and  
Veterans Affairs**

**FMO Design and Construction**

57024 Roosevelt Rd  
PO Box 5169  
JBER, AK 99505

Email: [jay.friesen@alaska.gov](mailto:jay.friesen@alaska.gov)

Issue Date: August 25, 2022

ATTN: Vendors

**RE:**      **Project Name:**                      Nome Armory Emergency Backup Generator  
             **Project Number:**                02C5521002  
             **Project Location:**              Nome, Alaska

**Addendum # One (1)**

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. The specifications in the General Requirements state that the Armory has a 400 amp 3 Phase service. It actually has a 400 amp single phase service.
2. The generator will only be for the Armory at this time. The OMS and maintenance shop will not be included in this offering.

This addendum is considered part of the Request for Proposal (RFP) and is to be acknowledge on your bid proposal.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

End of Addendum