



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Military and
Veterans Affairs**

FMO Design and Construction

57024 Roosevelt Rd
PO Box 5169
JBER, AK 99505

Email: jay.friesen@alaska.gov

Issue Date: August 25, 2022

ATTN: Vendors

RE: **Project Name:** Nome AAOF Emergency Backup Generator
 Project Number: 02C5521002
 Project Location: Nome, Alaska

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. The specifications in the General Requirements state that the Armory has a 400 amp 3 Phase service. It actually has a 600 amp Three phase service.

This addendum is considered part of the Request for Proposal (RFP) and is to be acknowledge on your bid proposal.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

End of Addendum