

## Department of Military and Veterans Affairs

FMO Design and Construction 57024 Roosevelt Rd PO Box 5169 JBER, AK 99505

Email: jay.friesen@alaska.gov

Issue Date: August 25, 2022

ATTN: Vendors

RE: Project Name: Utquigvik Armory & Barracks Emergency Backup Generator

Project Number: 0261120002
Project Location: Utquiagvik, Alaska

## Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issueddocuments, this addendum shall take precedence.

The following additions are required:

 The specifications in the General Requirements state that the Armory has a 200 amp single Phase service. The Armory has a 100 amp single phase and the barracks has a 200 amp single phase. An automatic ATS switch will be required for each service.

This addendum is considered part of the Request for Proposal (RFP) and is to be acknowledge on your bid proposal.

Please contact me if you have any questions.

Sincerely

Jay Friesen

**Building Management Specialist** 

907-428-7198

End of Addendum