



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Military and
Veterans Affairs**

FMO Design and Construction

57024 Roosevelt Rd

PO Box 5169

JBER, AK 99505

Email: jay.friesen@alaska.gov

Issue Date: August 31, 2002

ATTN: Vendors

RE: **Project Name:** Ketchikan Armory Emergency Backup Generator
 Project Number: 02B6520024
 Project Location: Ketchikan, Alaska

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. In the general requirements it states the contractor is to install a 400 amp three phase ATS. This will be changed to read: Install a 200 amp 120/240 volt three phase ATS.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

End of Addendum