



THE STATE  
of **ALASKA**  
GOVERNOR MIKE DUNLEAVY

**Department of Military and  
Veterans Affairs**

**FMO Design and Construction**

57024 Roosevelt Rd  
PO Box 5169  
JBER, AK 99505

Email: [jay.friesen@alaska.gov](mailto:jay.friesen@alaska.gov)

Issue Date: September 7, 2022

ATTN: Vendors

**RE:**      **Project Name:**                      Ketchikan Armory Emergency Backup Generator  
             **Project Number:**                02B6520024  
             **Project Location:**              Ketchikan, Alaska

**Addendum # One (1)**

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

- In the General Conditions Part 1.02.C.5 it reads: "Generator set to include an onboard automatic battery charger, engine block heater, and load bank." **The load bank requirement is to be deleted.**

Bidders are required to acknowledge receipt of this addenda on the proposal/bid form. If you do not acknowledge receipt of this addendum your bid will be considered non-responsive.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

