



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Military and
Veterans Affairs**

FMO Design and Construction

57024 Roosevelt Rd
PO Box 5169
JBER, AK 99505

Email: jay.friesen@alaska.gov

Issue Date: September 7, 2022

ATTN: Vendors

RE: **Project Name:** Utquigvik Armory & Barracks Emergency Backup Generator
 Project Number: **0261120002**
 Project Location: Utquiagvik, Alaska

Addendum # Two (2)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

1. The specifications in the General Requirements Part 1,C,2 give the generator requirements as peak load plus 25%. This requirement is to be amended to read 50% of peak load plus 25%.
2. In the General Conditions Part 1.02.C.5 it reads: "Generator set to include an onboard automatic battery charger, engine block heater, and load bank." **The load bank requirement is to be deleted.**

This addendum needs to be acknowledged in your bidding documents.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

End of Addendum