



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Military and
Veterans Affairs**

FMO Design and Construction

57024 Roosevelt Rd
PO Box 5169
JBER, AK 99505

Email: jay.friesen@alaska.gov

Issue Date: September 7, 2022

ATTN: Vendors

RE: **Project Name:** Nome AAOF Emergency Backup Generator
 Project Number: 02C5521002
 Project Location: Nome, Alaska

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

- The following additions are required:
- In the General Conditions Part 1.02.C.5 it reads: "Generator set to include an onboard automatic battery charger, engine block heater, and load bank." **The load bank requirement is to be deleted.**
- In the General Conditions Part 1.02.C.15 It reads: Provide and install 400-amp, 120/240-volt, single phase automatic and manual transfer switch. It is to read Install 600 amp 120/208 volt manual and automatic transfer switch.

Bidders are required to acknowledge receipt of this addenda on the proposal/bid form. If you do not acknowledge receipt of this addendum your bid will be considered non-responsive.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

End of Addendum