



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Military and
Veterans Affairs**

FMO Design and Construction

57024 Roosevelt Rd

PO Box 5169

JBER, AK 99505

Email: jay.friesen@alaska.gov

Issue Date: September 7, 2022

ATTN: Vendors

RE: Project Name: Kodiak Armory Emergency Backup Generator
Project Number: 02B8522040
Project Location: Kodiak, Alaska

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following additions are required:

- In the General Conditions Part 1.02.C.5 it reads: "Generator set to include an onboard automatic battery charger, engine block heater, and load bank." **The load bank requirement is to be deleted.**
- On the Payment Bond page there is a project number in the address block. This is a computer error and is to be deleted.
- On the Performance Bond page there is a project number in the Contact block. This is a computer error and is to be deleted.

Bidders are required to acknowledge receipt of this addenda on the proposal/bid form. If you do not acknowledge receipt of this addendum your bid will be considered non-responsive.

Please contact me if you have any questions.

Sincerely

Jay Friesen

Building Management Specialist

907-428-7198

