

STATE OF ALASKA

DEPARTMENT OF NATURAL RESOURCES
DIVISION OF SUPPORT SERVICES



INVITATION TO BID (ITB) 10-015-23

1000 Skies-Sunrise Phase 2 Road Construction

Addendum Three

Date of Issue: March 14, 2023

Addendum Three serves to answer a question from a vendor.

Important Note to Offerors: Only the ITB terms and conditions referenced in this addendum are being changed. All other terms and conditions of the ITB remain the same. This Addendum Three is hereby made part of the ITB and is a total of two pages.

Chris Brooks

Procurement Specialist 5

Phone: (907) 269-8666

Email: christopher.brooks@alaska.gov

Answer to Question from Vendor

Question 1: The typical section released with Addendum 2 shows a 36" minimum embankment fill. The previously released typical section showed 24". Which is correct?

Answer: 36" minimum embankment fill is correct. The typical section Rev 2, dated 03/06/2023 shall be used for this project.

End of Addendum Three