Department of Corrections DIVISION OF ADMINISTRATIVE SERVICES



Governor Mike Dunleavy

802 3rd Street, Suite 224 Douglas, Alaska 99824 Main: 907.465.6014 Email: <u>Michael.lim@alaska.gov</u>

Issue Date: May 1, 2023

ATTN: Vendors

RE: Project Name: Project Number: Project Location: ITB Deadline: HMCC Earthquake Repairs 2018-PR007891-1 Hiland Mountain Correctional Center May 5, 2023 @ 2:00 pm, Local Time

Addendum # Two (2)

The Department of Corrections (DOC) is issuing this Addendum to the Invitation to Bid (ITB) for the above project.

The following are questions from interested parties and the department's response.

Q: Can we use copper when repairing the heat lines? Or do we need to go back with existing steel for the heat lines?

A: Yes, DOC will allow the use of copper when repairing the heat lines.

Q: There are approximately 250 LF of CMU crack repair that needed to be addressed in the HMCC gym area. Normally these could be utilized by a spackling paste to be repair these type of hairline cracks. Since this repair is not structural, would this be an acceptable repair?

A: Spackling paste is acceptable.

Q: The ST Corridor location where 13' x 8' of drywall needs to be replaced still showing signs of water intrusion. Replacing the GWB at this location without addressing the water leakage issue will lead to a finish product that the vendor and / or its paining subcontractor will not provide a warranty for.

A: DOC understands vendor concern. No warranty is needed.

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your quote form.

Please contact me if you have any questions at michael.lim@alaska.gov or 907-465-6014.

Sincerely,

Michael I im

Michael Lim Procurement Specialist V

cc: William Merchant, Facilities Manager I, DOC Clif Reagle, Facilities Manager II, DOC

End of Addendum