Department of Corrections DIVISION OF ADMINISTRATIVE SERVICES



802 3rd Street, Suite 224 Douglas, Alaska 99824 Main: 907.465.6014 Email: <u>Michael.lim@alaska.gov</u>

Issue Date: May 4, 2023

ATTN: Vendors

RE: Project Name: Project Number: Project Location: ITB Deadline: HMCC Earthquake Repairs 2018-PR007891-1 Hiland Mountain Correctional Center May 5, 2023 @ 2:00 pm, Local Time

Addendum # Three (3)

The Department of Corrections (DOC) is issuing this Addendum to the Invitation to Bid (ITB) for the above project.

The following are questions from interested parties and the department's response.

Q: The Scope of work says the heating lines in the walkway area circulate water. As those areas are prone to freezing, can I verify it is indeed water in those heating lines and not glycol? If it is glycol, should new glycol be provided or is it okay to capture the existing and put back into the system once the new lines are in place?

A: Currently, water is in the heating lines.

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your quote form.

Please contact me if you have any questions at michael.lim@alaska.gov or 907-465-6014.

Sincerely,

Michael Lim

Michael Lim Procurement Specialist V

cc: William Merchant, Facilities Manager I, DOC Clif Reagle, Facilities Manager II, DOC

End of Addendum