



State of Alaska
Department of Environmental Conservation
Village Safe Water Program

555 Cordova Street
Anchorage, AK 99501
evan.patterson@alaska.gov

June 16, 2023

To: Vendor List

Re: Amendment 2
ITB 23-VSW-TLT-023
Tuluksak Water Treatment Plant / Washeteria Project
ITB Due Date: July 11, 2023 @ 2:00 PM AST

The following changes are required:

1. The ITB due date is extended from June 26, 2023 to July 11, 2023 @ 2:00 PM AST.

The following are vendor questions and the department's response:

1. Vendor: Looking through the addendum and project plans, I don't see any civil drawings or material list for the insulated pipe and fittings that will be required.

Would you be able to provide plan sheets detailing the arctic pipe on this project?

Department: The arctic pipe sections and fittings are shown on sheets C501 -506. The site plan on sheet C105 shows the layout for most of the pipe lines. The water storage tank pipes are shown on C107, the waste heat recovery loop piping is shown on C401, the raw water line is shown on CW401, the water main and service lines are shown on CW402-404 and CW530, and the sewage force main is shown on CS401. There are no material lists for the project.

2. Vendor: Shop Fabrication Plans Sheet 3.07 appears to be missing content. Specs Volume 2 Section 262913 was duplicated with differences (pages 70-74 & 70-82).

Department: There is no special blocking for Module 3 which is why Shop Fabrication Plans sheet 3.07 is blank.

The second specification Volume 2, Divisions 26 – 46, section 26 29 13 ENCLOSED CONTROLLER (PDF page 78-82) is a duplicate of the previous section (PDF pages 70-74) and shall be disregarded.

3. Vendor: I'm wondering if the 12k Gallon Double Walled Tank is already purchased, or if I should expect a few phone calls or RFQ's for the project.

Department: The tank has not been purchased. The bidding contractor shall be responsible for procuring the tank.

4. Vendor: Would like to ask for an extension of the bid date till after the holidays possibly 11th. of July if possible?

Department: Approved, see above #1 Required Changes.

Evan Patterson



Procurement Specialist