



THE STATE  
of **ALASKA**  
GOVERNOR MIKE DUNLEAVY

**Department of Corrections**  
**DIVISION OF ADMINISTRATIVE SERVICES**

802 3<sup>rd</sup> Street, Suite 224  
Douglas, Alaska 99824  
Main: 907.465.6014  
Email: [Michael.lim@alaska.gov](mailto:Michael.lim@alaska.gov)

Issue Date: June 20, 2023

ATTN: Vendors

**RE: Project Name:** PMCF Septic System Replacement  
**Project Number:** 230005932  
**Project Location:** Point Mackenzie Correctional Farm

**ITB Opening Date and Time: June 21, 2023 @ 2:00 p.m. Alaska Time.**

**Addendum # One (1)**

The Department of Corrections is issuing this Addendum to the Invitation to Bid (ITB) for the above project.

The following are questions from interested parties and the department's response.

Q: Section 01000, General Requirements, Scope of Work #13 and #14: Please provide some indication of how much pumping will be required. Will contractor be responsible for pumping after award or after work onsite begins?

*A: Approximately 4500 gallons a day will be required. Contractor will be responsible for pumping when onsite works begins.*

Q: Section 00800 – Supplemental Conditions, Modifications to the General Conditions, SC-7.2 – Permits Licenses and Taxes, Page 00800-4, Paragraph A -2: Please clarify why a State of Alaska Fire Marshal Plan Review will be necessary.

*A: Not required. Please remove from the ITB and its entirety.*

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledge on your quote form.

Please contact me if you have any questions at [Michael.lim@alaska.gov](mailto:Michael.lim@alaska.gov) or 907-465-6014.

Sincerely,

*Michael Lim*

Michael Lim  
Procurement Specialist V

cc: John Gard, Facilities Manager I, DOC  
Clif Reagle, Facilities Manager II, DOC

**End of Addendum**