



State of Alaska
Department of Environmental Conservation
Village Safe Water Program

555 Cordova Street
Anchorage, AK 99501
evan.patterson@alaska.gov

July 3, 2023

To: Vendor List

Re: Amendment 3
ITB 23-VSW-MCG-028
McGrath Wastewater Improvements
ITB Due Date: July 6, 2023 @ 2:00 PM AST

The following are vendor questions and the department's response:

1. Vendor: The ITB speaks to the Owner furnished materials > Step Systems (page 2 of 2).
Are the Step System (Pump) Control Panels (shown in sheet drawing C1.0) provided in the STEP SYSTEM package?

Department: Yes

2. Vendor: Are the Heat Trace Panels / Points existing?

Department: Yes. The Heat Trace Panels / Points shown on the drawings are to be furnished by the contractor. The existing Heat Trace Power Points are non-functional and are to be abandoned.

3. Vendor: Does the Contractor need to provide Heat Trace Panels / Points?

Department: Yes. See above answer.

4. Vendor: Drawing Sheet G2.0 Center of the drawing Note speaks to Amos Ave Heat Trace Power Point Improvements. Drawing Sheet E2.1 and E2.2 show Simplex Controls, Heat Trace Powerline diagrams and associated Racks. Is the Contractor to provide the equipment/materials shown on E2.1 and E2.2 > details 1 through 4.

Department: Yes. Any Materials not specifically listed as being owner-furnished are to be furnished by the contractor.

Evan Patterson

Evan Patterson

Procurement Specialist