



**State of Alaska  
Department of Environmental Conservation  
Village Safe Water Program**

555 Cordova Street  
Anchorage, AK 99501  
[evan.patterson@alaska.gov](mailto:evan.patterson@alaska.gov)

July 11, 2023

To: Vendor List

Re: Amendment 4  
ITB 23-VSW-TLT-023  
Tuluksak Water Treatment Plant / Washeteria Project  
ITB Due Date: July 18, 2023 @ 2:00 PM AST

**The following are vendor questions and the department's response:**

1. Vendor: What is the building snow load for Tuluksak or who is the governing authority? The following snippet in the specs is in relation to the metal roof panels section 07 41 10, item 1.5. As roof panels this would not be in relation to the bolted steel tank, however are there drift loads we need to be aware of?

Department: See Design Criteria Table on Drawing S001, and use those loads in place of the loads identified in specification section 07 41 10-2, Part 1.5, Item E. Design Criteria. Specification section 07 41 10 only applies to the metal roof for the WTP/W building, not the water storage tank. See Drawings CW510 and CW512 for the water storage tank roof design. Drift loads do not need to be considered for the water storage tank.

Evan Patterson

*Evan Patterson*

Procurement Specialist