



THE STATE  
of **ALASKA**  
GOVERNOR MIKE DUNLEAVY

## Department of Military and Veterans Affairs

FMO Design and Construction  
57024 Roosevelt Rd  
PO Box 5169 JBER, AK 99505

Email: johann.mueller@alaska.gov

Issue Date: September 6, 2023

ATTN: Vendors

**RE: Project Name:** Camp Denali – Building 49150 CSMS Parking Lot Crack Seal  
**Project Number:** 02A8023005  
**Project Location:** Camp Denali – Building 49150 CSMS, JBER, Alaska

### **Addendum # One (1)**

**Important Note to Bidders:** **Bidders are required to acknowledge receipt of this addendum on the quote submittal form.** It is the bidder's responsibility to review and accept all addenda to this solicitation. If you do not acknowledge receipt of this addendum your quote may be considered nonresponsive. This addendum is being issued to recognize changes and/or answer questions to the Invitation to Bid (ITB). Only the ITB terms and conditions referenced in this addendum are being changed. All other terms and conditions of the ITB remain the same.

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

### **The following changes are required:**

1. The response requirement for the **Deadline for Receipt of Bids** has been extended to September 14, 2023, at 2 pm Alaska time.
2. Contractor shall perform crack routing at a minimum of 1/2" x 1/2" in preparation for the crack-sealing methods/requirements of UFC 3-270-01.

Please contact me if you have any questions.

Sincerely,

Johann Mueller  
Building Management Specialist  
Facility Management Office, State of Alaska, DMVA  
57024 Roosevelt Road, JBER, AK 99505  
Email: johann.mueller@alaska.gov  
Work: 907-428-7697  
Cell: 907-744-9073

**End of Addendum**