

## Department of Corrections DIVISION OF ADMINISTRATIVE SERVICES

802 3<sup>rd</sup> Street, Suite 224 Douglas, Alaska 99824 Main: 907.465.6014

Email: Michael.lim@alaska.gov

Issue Date: January 10, 2024

ATTN: Vendors

RE: Project Name: FCC & LCCC Fence Detection System

**Project Number:** 230006056-57

Project Location: Fairbanks Correctional Center (FCC), Fairbanks, Alaska
Lemon Creek Correctional Center (LCCC), Juneau, Alaska

ITB Deadline: January 17, 2024 @ 2:00 p.m., Local Time

## Addendum # 2 (Two)

The Department of Corrections is issuing this Addendum to the Invitation to Bid (ITB) for the above project:

1. Delete questions / answers for questions #2 on addendum #1 and replace with:

Section 00312: Bid Schedule Document - Page 1 of 2 and page 2 of 2.

- A. Basic Bid. Should this Basic bid include all of the Control equipment including analyzers for Additive Alternate #1 and Additive Alternate #2?
- B. Basic Bid. Should this Basic bid include all of electrical wiring (additional conductor pairs) that will be required for Additive Alternate #1 and Additive Alternate #2?
- C. Basic Bid. A double run of Detekion sensor cable is required to accommodate the height of the inner perimeter fence (if the Alternates are not accepted). If the answer to questions 3A and 3B is yes and the Alternates are Not accepted then does the AK DOC want the top run of the DeTekion sensor cable to be connected to the analyzers that may be used in the future for the Sensor Coil (i.e. to be independent of the bottom sensor cable run)? This will facilitate a Detekion sensor cable hybrid and in the future when funds are available the Sensor Coil can be connected to these analyzers and the excess Detekion sensor cable can be used for spares.
- D. Additive Alternates #1 & #2: These alternates refer to Section 1000, 1.10. Section 1000, 1.10 states that there are No Alternates. Please advise.

## Response:

- A: No.
- B: Yes.
- C: No.
- D: Please refer to Addendum #1, Item #2 response (ALTERNATES).

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your quote form.

Please contact me if you have any questions at <a href="michael.lim@alaska.gov">michael.lim@alaska.gov</a> or 907-465-6014.

Sincerely,

Michael Lim

Procurement Specialist V

Michael Lim

cc: William Merchant, Facilities Manager II, DOC Shawn Ratliff, Facilities Manager I, DOC

Jeffey Watson, FCC Maintenance Supervisor Jacob Scanlon, LCCC Maintenance Supervisor

**End of Addendum**